Mandatory Language for Public Notice

Triggered Source Monitoring and Reporting Violation: Groundwater Rule

City of Evant PWS 0500015 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during April 2020. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active groundwater well source. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

**What should I do?**

There is nothing you need to do at this time.

**What is being done?**

The City of Evant has increased employee accountability and training as well as changes in staff to help eliminate future violations.

For more information, please contact Scot Stegemoller at 254-216-5369 or 598 E Hwy 84 Evant, TX

**Mandatory Language for Monitoring and Reporting Violation**
**Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)**
**MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The **City of Evant** water system PWS ID **0500015** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This/These violation(s) occurred in the monitoring period(s) 1/1/2020 to 3/31/2020

We are taking the following actions to address this issue:

**The City of Evant has increased employee accountability and training as well as changes in staff to help eliminate future violations. The city has also implemented a more effective system of monitoring and record keeping.**

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Scot Stegemoller at 254-216-5369**

Posted /Delivered on: *8/27/2021*